

**GOVERNMENT OF ANDHRA PRADESH**  
**STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT**

From:  
The Director General,  
State Disaster Response & Fire Services  
Andhra Pradesh, Vijayawada.

To:  
The Management,  
M/s Kreda the School, located at  
Sy.No.444/1, Dinnevarapadu Village,  
Kurnool District.

**Rc.No.6115/MSB/SR/KNL/2021, Dated : 03-06-2022.**

Sir,

Sub:- A.P. State Disaster Response and Fire Services Department-MSB Section-Kurnool District- Change of Name from **CBSE School Building & State School Building to Kreda the School**, Sy.No.444/1, Dinnevarapadu Village, Kurnool District -Regarding.

- Ref:- 1) This Office No Objection Certificate for Occupancy Block-1 CBSE School & Block-2 State School Building issued vide Rc. No. 6115/MSB/SR/KNL/2021, Dated: 22-12-2020.  
2) Name Change proposal of M/s Kreda the School, located at Sy.No.444/1, Dinnevarapadu Village, Kurnool District.


<< 0 >>

The Management of M/s Kreda the School, located at Sy.No.444/1, Dinnevarapadu Village, Kurnool District has informed that they have changed their Educational name from **CBSE School Building & State School Building to Kreda the School**, they requested to update the name of their Building in Fire No Objection Certificate. The Management has remitted the Fire Precautionary Fee of Rs. 6,000/- vide Challan No.61083606502022 Dated.02-06-2022 and towards the change of name, into Government account through online payment as per G.O.Ms.No.71 Home (Prisons-A) Dept., Dt.01-04-2010.

2) The Management Obtained NOC for Occupancy from this Department Vide ref 1<sup>st</sup> cited to the existing building in the name of M/s CBSE School Building & State School Building, located at Sy.No.444/1, Dinnevarapadu Village, Kurnool District for 2 Blocks ie., Block -1 & Block -2, with heights of 16.49 Sq.Mtrs., and total built-up area of 11772.78 Sq.Mtrs, for Educational Occupancy.

3) Under the above circumstances, and as per rule 20 of A.P. Fire and Emergency Operations and Levy of Fee Rules, 2006, this office has **NO OBJECTION** to the change of name from **CBSE School Building & State School Building to Kreda the School**, of the same premises. The Management is instructed to fulfill the Fire Safety Measures in the same Building ie., located at Sy.No.444/1, Dinnevarapadu Village, Kurnool District as mentioned in No Objection Certificate for Occupancy by this Department vide reference 1<sup>st</sup> cited.

Yours sincerely,



Director General,  
State Disaster Response & Fire Services,  
Andhra Pradesh, Vijayawada

Copy to :

- (i). The Regional Fire Officer, Southern Region, Vijayawada.
- (ii). The District Fire Officer, Kurnool District.



**GOVERNMENT OF ANDHRA PRADESH**  
**A.P. STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT**

From:  
The Director General,  
State Disaster Response & Fire Services,  
Andhra Pradesh, Vijayawada.

To:  
Smt T.G.Silpa Bharath,  
CBSE School Building and  
State School Building,  
Sy.No.444/1, Dinnedevapuradu  
Village, Kurnool District.

**Rc.No.6115/MSB/SR/KNL/2021, Dated.22-12-2021.**

Sir,

Sub:- A.P.STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT MSB  
Section-Eastern Region-Issuance of No Objection Certificate for Occupancy to  
the Existing Multi Storied Building of M/s CBSE School Building & State  
School Building, Sy.No.444/1, Dinnedevapuradu Village and Kurnool District  
-Regarding.

- Ref:- 1. Provisional NOC File No.10709/KNL/MSB/2019, Dated:17-12-2019 of  
Director General, State Disaster Response & Fire Services, AP.,  
Vijayawada.  
2. Application of M/s CBSE School Building & State School Building,  
Sy.No.444/1, Dinnedevapuradu Village and Kurnool District.  
3. This Office Memo Rc. No. 6115/MSB/SR/KNL/2021, Dated.22-11-2021.  
4. MSB Inspection Committee Report Rc. No. 29/SFO/SSLM/2021, Dt:03-  
12-2021.

<<O>>

The Management has requested for issuance of No Objection Certificate for  
Occupancy to the existing Building of M/s CBSE School Building & State School  
Building, Sy.No.444/1, Dinnedevapuradu Village and Kurnool District in the reference  
2<sup>nd</sup> cited.

2) The Management has obtained Provisional No Objection Certificate from this  
Department vide reference 1<sup>st</sup> cited for construction of the building for two Blocks. The  
CBSE school building with Pseudo stilt Floor + Ground+ 4 upper floors with a height of  
16.49 Mtrs., with total built up area of 5912.58 Sq Mtrs., and the State School Building  
with Pseudo stilt Floor + Ground+ 4 upper floors with a height of 16.49 Mtrs., with total  
built up area of 5860.20 Sq Mtrs., and now applied for No Objection Certificate for  
Occupancy.

3) The Inspection Committee has inspected the premises of M/s CBSE School  
Building & State School Building, Sy.No.444/1, Dinnedevapuradu Village and Kurnool  
District on 03-12-2021 and submitted the following report vide reference 4<sup>th</sup> cited.

4) The Management has constructed a Multi Storied Building with following (05) Blocks.

Sl. No.	Block Name	Height of the Building in Mtrs.,	No. of Floors	Built up area in Sq.Mtrs.,
1	Block-I CBSE school building	16.49	Pseudo stilt Floor + Ground+ 4 upper floors	5912.58
2	Block-II State School Building	16.49	Pseudo stilt Floor + Ground+ 4 upper floors	5860.20
<b>Total:</b>				<b>11,772.78</b>

Contd..2p

**BLOCK - I (CBSE school building)**

**5) Particulars of the building:**

a) Address of the Building	:	Block-I (CBSE school building)
b) Height of the building	:	16.49meters
c) No. of Floors	:	Pseudo stilt Floor + Ground+ 4 upper floors
d) Type of Occupancy	:	Educational (B1)

**6) The Builder has provided the following Means of Escape.**

Sl. No.	Details of Means of Escape	Minimum width required		Provided	
		Nos.	Width in meters	Nos.	Width in meters
1	Internal Staircase	1No	01.50 Mtrs.,	01	01.98
2	External Staircase	1No	01.50 Mtrs.,	01	01.98

**7) The details of Occupant Load per Unit and Exit Width required and provided is furnished as below:**

Sl. No.	Floor	Built-up area in Sq.Mtrs.,	Type of Occupancy	No. of Occupants	Means of escape Required in Mtrs.,	Provided in Mtrs.,
1	Pseudo Stilt Floor	962.03	Parking	10	Parking	03.96
2	Ground	990.11	Educational	200	02.00	03.96
3	1st Floor	990.11	Educational	200	02.00	03.96
4	2nd Floor	990.11	Educational	200	02.00	03.96
5	3rd Floor	990.11	Educational	200	02.00	03.96
6	4th Floor	990.11	Educational	200	02.00	03.96
<b>Total</b>		<b>5912.58</b>				

**8) The Management has provided the following Fire Fighting Equipment keeping in view of practicality, maintenance and resilience.**

Sl No	Fire Fighting Equipment	Prescribed	Provided	Deficit
1	Fire Extinguishers	ABC type	60 Nos.	Nil
2	Underground parking /Cellar / Basement	Temperature Sensors connected "Hooter" and that can give alerts through cell phone	required	To be provided
3	Manual Call point	One number per floor	12 Nos.	Nil
4	Under Ground Static Water Tank (or) Terrace Water Tank	5,000 Ltrs (minimum)	25,000 Ltrs. at Terrace Tank	Nil
5	2 HP (Pump + Electrical Motors connected) @ one per floor connected to normal plumbing system instead of down comer/special pipes.	One per each floor (Total 6 floors)	02 Nos.	03 Nos.
6	5 HP (Mobile Pump + Petrol Engine on wheels by connecting at Ground floor sump)	One number at Ground floor	required	01 No.

Contd...3p



9) The Management has provided the following Electrical Safety system.

(i) Miniature Circuit Breakers, MCBs	: Provided
(ii) No overloading of Power sockets	: Yes
(iii) 10 years old wiring to be changed specially wherever A/c is there ?	: Provided
(iv) LED Lights in closed Rooms, Corridors, Staircases connected to Inverter (Battery)	: Provided
(v) Grounding/Earthing is provided	: Provided
(vi) Lightning Conductor is provided	: Provided
(vii) The above shall be certified by authorized Electrical Contractor/Supervisor.	: Yes

**BLOCK - II (State School Building)**

10) **Particulars of the building:**

a) Address of the Building	: Block-II (State School Building)
b) Height of the building	: 16.49meters
c) No. of Floors	: Pseudo stilt Floor + Ground+ 4 upper floors
d) Type of Occupancy	: Educational (B1)

11) The Builder has provided the following Means of Escape.

Sl. No.	Details of Means of Escape	Minimum width required		Provided	
		Nos.	Width in meters	Nos.	Width in meters
1	Internal Staircase	1No	01.50 Mtrs.,	01	01.98
2	External Staircase	1No	01.50 Mtrs.,	01	01.98

12) The details of Occupant Load per Unit and Exit Width required and provided is furnished as below:

Sl. No.	Floor	Built-up area in Sq.Mtrs.,	Type of Occupancy	No. of Occupants	Means of escape Required in Mtrs.,	Provided in Mtrs.,
1	Pseudo Stilt Floor	953.30	Parking	10	Parking	03.96
2	Ground	981.38	Educational	200	02.00	03.96
3	1 <sup>st</sup> Floor	981.38	Educational	200	02.00	03.96
4	2 <sup>nd</sup> Floor	981.38	Educational	50	02.00	03.96
5	3 <sup>rd</sup> Floor	981.38	Educational	50	02.00	03.96
6	4 <sup>th</sup> Floor	981.38	Educational	50	02.00	03.96
	<b>Total</b>	<b>5860.20</b>				

13) The Management has provided the following Fire Fighting Equipment keeping in view of practicality, maintenance and resilience.

Sl No	Fire Fighting Equipment	Prescribed	Provided	Deficit
1	Fire Extinguishers	ABC type	60 Nos.	Nil
2	Underground parking /Cellar / Basement	Temperature Sensors connected "Hooter" and that can give alerts through cell phone	required	To be provided
3	Manual Call point	One number per floor	12 Nos.	Nil
4	Under Ground Static Water Tank (or) Terrace Water Tank	5,000 Ltrs (minimum)	25,000 Ltrs. at Terrace Tank	Nil

Contd...4p



Sl No	Fire Fighting Equipment	Prescribed	Provided	Deficit
5	2 HP (Pump + Electrical Motors connected) @ one per floor connected to normal plumbing system instead of down comer/special pipes.	One per each floor (Total 6 floors)	02 Nos.	03 Nos.
6	5 HP (Mobile Pump + Petrol Engine on wheels by connecting at Ground floor sump)	One number at Ground floor	required	01 No.

14) The Management has provided the following Electrical Safety system.

(i) Miniature Circuit Breakers, MCBs	:	Provided
(ii) No overloading of Power sockets	:	Yes
(iii) 10 years old wiring to be changed specially wherever A/c is there ?	:	Provided
(iv) LED Lights in closed Rooms, Corridors, Staircases connected to Inverter (Battery)	:	Provided
(v) Grounding/Earthing is provided	:	Provided
(vi) Lightning Conductor is provided	:	Provided
(vii) The above shall be certified by authorized Electrical Contractor/Supervisor.	:	Yes

15) The inspection committee has tested the provided fire safety systems and found in working condition.

16) It is the responsibility of the Management to ensure the above Fire Safety Measures and maintain them in good working condition in the above Educational Building. The Management is responsible all risks involved in case of Fire Accidents.

17) In view of the above and taking into the consideration of larger public interest and in context of the COVID-19 Pandemic Crisis across the country due to an acute shortage of beds to the patients and also based on the inspection committee report, the No Objection Certificate for Occupancy is issued to the existing building belongs to Smt T.G.Silpa of M/s CBSE School Building & State School Building, Sy.No.444/1, Dinnevarapudu Village and Kurnool District for a period of (05) years, subject to the appropriate building permission from Municipal Corporation and the Fire safety systems mentioned above shall be provided within one year and report submit to this office.

18) This No Objection Certificate is issued, subject to the outcome of O.As/W.Ps etc., if any, before Courts etc.,

19) It is informed that, the Management of M/s CBSE School Building & State School Building, Sy.No.444/1, Dinnevarapudu Village and Kurnool District is requested to maintain the following conditions compulsorily for safety purpose.

Contd...5p

As Builder	As occupant	As Security Personnel
All the fire protection arrangements shall be maintained in good condition at all times.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must train in correct method of operation of the fire fighting system installed.
Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
This No objection Certificate for occupancy is issued from fire safety point of view.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

15) This No Objection Certificate for Occupancy is valid for a period of Five years only from the date of issue of this letter subject to the compliance of above Fire and Electrical Safety Measures. The owner/ Occupier/Builder/Management concerned of the building shall submit self declaration/ Certification with regard to working condition of fire safety measures every year in the prescribed format and submit/upload the photographs of the Mock drills conducted in the premises. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.90, Home (Prisons & Fire) Department, dated.13-08-2021 and G.O.Ms.No.120, Home (Prisons & Fire) Department, dated.25-10-2021 before expiry of this No Objection Certificate.

Yours sincerely,

Director General,

State Disaster Response and Fire Services,  
Andhra Pradesh, Vijayawada.

Copy to the Vice Chairman, Kurnool Urban Development Authority, C.R.C. Building,  
Chanikyapuri Colony, A-Camp, Kurnool District.

Copy to Smt T.G.Silpa Bharath, W/o Sri T.G.Bharath, D.No.43-262, New Sankal Bagh,  
NR Peta, Kurnool-518004

Copy to the Regional Fire Officer, Southern Region, Vijayawada.

Copy to District Fire Officer, Kurnool District.

**Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.**